



Progress Report

Client: Jurys Inn

Facility: The Midland Hotel Manchester

Report Date: 28/04/2019

Roof Section: Main Roof

Report Data

Title	Progress Report 25-4-19
-------	-------------------------

Latest site visit carried out by Tom Boon and Daniel Crowley, regional technical manager for the Garland Company on Thursday 25th of April.

Time of Site Visit: 10:00 am

N.o of operatives on Site: 3 roofers

Weather Conditions: 12 degrees - showers

General Comments:

I visited the site to go over the general progress of works with the operatives on site. Work is progressing at a great rate the contractors have now fully stripped the final area of the back mezzanine installed the VCL, base sheet and part of the cap sheet.

I took the time to walk all the completed areas physically pulling at the laps which all display a great bleed out and bond the substrate, all area have been well primed and upstand heights have been achieved

I really happy with all the detailing work in this area, the contractor has taken care to ensure a tidy finish, especially around the dome penetrations.

I will be attending site again later this week to provide further updates



Photo 1

Overview of roof section



Photo 2

Overview of roof section



Photo 3

required bleed out achieved



Photo 4

All upstand membranes are well bonded



Photo 5

Sole plate has been used



Photo 6

Great detailing around this section



Photo 7

Base sheet is well bonded in this area